


CERTIFICATE OF CONFORMITY

Issued to: Huawei Digital Power Technologies Co., Ltd.
Office 01, 39th Floor, Block A, Antuoshan Headquarters Towers, 33 Antuoshan 6th Road, Futian District, Shenzhen, 518043, P.R. China

For the product: Smart PCS

Trade name: 
HUAWEI

Type/Model: PCS2000-108K-MB1

Ratings: See Annex

Manufactured by: Huawei Digital Power Technologies Co., Ltd.
Office 01, 39th Floor, Block A, Antuoshan Headquarters Towers, 33 Antuoshan 6th Road, Futian District, Shenzhen, 518043, P.R. China

Requirements: Engineering Recommendation G99 Issue 1 – Amendment 10:2024 (G99/1-10:2024)
(Requirements for Type A Generating Module)

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6199027.50.

The examination has been carried out on one single specimen of the product. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This Test Certificate expires at the latest on 27 November 2029 or expires upon withdrawal of one of the above mentioned standards.

Shanghai, 18 November 2024

Number: 6199027.01COC

DEKRA Testing and Certification (Shanghai) Ltd.


Cliff Lin
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed



Document no. : 6199027.01COC

Ratings of the test product:

Operating temperature range: - 25°C to + 65°C

Protective class: I

Ingress protection rating: IP55

Power factor range (adjustable): 1 leading...1 lagging

Overvoltage category: III(Mains), II(DC)

Operating altitude: 4000 m

Inverter Topology: Non-Isolation

PCS2000-108K-MB1:

Input port: max. voltage 1100 V, max. continuous current 187.1 A, Operating range 550 -950 V

Output port: nominal voltage 380/400/415 V, 420/440/480 V, 50/60 Hz, rated power 108 kW,
rated apparent power 108 kVA, rated current 164.1 A, 380 Vac; 155.9 A, 400 Vac; 150.3 A 415 Vac;
148.5 A, 420 Vac; 141.8 A, 440 Vac; 130.0 A, 480 Vac;

Document no. : 6199027.01COC

G99/1-10 A2-3 Compliance Verification Report –Tests for Type A Inverter Connected Power Generating Modules	
Extract form test report number:	6199027.50

Model: PCS2000-108K-MB1				P	
Test 1:					
Measured Voltage (V)		Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (seconds)
L1	195.91	47.00	108576.64	1.000	20
L2	195.68				
L3	195.69				
Test 2:					
Measured Voltage (V)		Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (Minutes)
L1	195.89	47.50	108573.01	1.000	90
L2	195.64				
L3	195.65				
Test 3:					
Measured Voltage (V)		Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (Minutes)
L1	253.26	51.49	108431.93	1.000	90
L2	253.08				
L3	253.08				
Test 4:					
Measured Voltage (V)		Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (Minutes)
L1	253.39	52.00	108595.18	1.000	15
L2	253.19				
L3	253.19				
Test 5:					
Measured Voltage (V)		Measured Frequency (Hz)	Measured Power (W)	Measured Power factor	Test Time (Minutes)
L1	230.38	50.00	108574.31	1.000	90
L2	230.20				
L3	230.20				
Test 6:					
Measured Voltage (V)	Ramp range	Test frequency ramp	Test Duration	Confirm no trip	
195.77	47.0 Hz to 52.0 Hz	+1 Hzs ⁻¹	5.0 s	No trip	
253.24	52.0 Hz to 49.0 Hz	-1 Hzs ⁻¹	3.0 s	No trip	

Document no. : 6199027.01COC

2. Power Quality – Harmonics:								P	
<p>For Power Generating Modules of Registered Capacity of less than 75 A per phase (ie 50 kW) the test requirements are specified in Annex A.7.1.5. These tests should be carried out as specified in BS EN 61000-3-12, and measurements for the 2nd – 13th harmonics should be provided. The results need to comply with the limits of Table 2 of BS EN 61000-3-12 for single phase equipment and Table 3 of BS EN 61000-3-12 for three phase equipment. For three phase Power Generating Modules, measurements for all phases should be provided.</p> <p>For Power Generating Modules of Registered Capacity of greater than 75 A per phase (ie 50 kW) the installation must be designed in accordance with EREC G5.</p> <p>The rating of the Power Generating Module (per phase) should be provided below, and the Total Harmonic Distortion (THD) and Partial Weighted Harmonic Distortion (PWHD) should be provided at the bottom of this section.</p>									
Model: PCS2000-108K-MB1									
Power Generating Module tested to BS EN 61000-3-12									
Power Generating Module rating per phase (rpp)				36		kVA		Harmonic % = Measured Value (A) x 23/rating per phase (kVA)	
Single or three phase measurements (for single phase measurements, only complete L1 columns below)				Three-phase inverter					
Harmonic	At 45-55% of Registered Capacity						Limit in BS EN 61000-3-12		
	Measured Value (MV) in Amps			Measured Value (MV) in %					
	L1	L2	L3	L1	L2	L3	1 phase	3 phase	
2	0.154	0.121	0.059	0.098	0.077	0.038	8%	8%	
3	0.099	0.071	0.051	0.063	0.045	0.033	21.6%	Not stated	
4	0.246	0.236	0.260	0.157	0.151	0.166	4%	4%	
5	0.203	0.205	0.204	0.130	0.131	0.130	10.7%	10.7%	
6	0.014	0.072	0.070	0.009	0.046	0.045	2.67%	2.67%	
7	0.104	0.094	0.052	0.066	0.060	0.033	7.2%	7.2%	
8	0.040	0.034	0.027	0.026	0.022	0.017	2%	2%	
9	0.099	0.138	0.084	0.063	0.088	0.054	3.8%	Not stated	
10	0.086	0.082	0.042	0.055	0.052	0.027	1.6%	1.6%	
11	0.520	0.550	0.538	0.332	0.351	0.344	3.1%	3.1%	
12	0.020	0.018	0.020	0.013	0.012	0.013	1.33%	1.33%	
13	0.327	0.284	0.296	0.209	0.181	0.189	2%	2%	
THD	-	-	-	0.47%	0.47%	0.46%	23%	13%	
PWHD	-	-	-	1.45%	1.46%	1.42%	23%	22%	

THD = Total Harmonic Distortion

PWHD = Partial Weighted Harmonic Distortion

Document no. : 6199027.01COC

Harmonic	At 100% of Registered Capacity						Limit in BS EN 61000-3-12	
	Measured Value (MV) in Amps			Measured Value (MV) in %			1 phase	3 phase
	L1	L2	L3	L1	L2	L3		
2	0.490	0.587	0.293	0.313	0.375	0.187	8%	8%
3	0.184	0.143	0.126	0.118	0.091	0.081	21.6%	Not stated
4	0.615	0.486	0.575	0.393	0.310	0.367	4%	4%
5	0.305	0.322	0.305	0.195	0.206	0.195	10.7%	10.7%
6	0.160	0.062	0.141	0.103	0.040	0.090	2.67%	2.67%
7	0.151	0.139	0.098	0.097	0.089	0.062	7.2%	7.2%
8	0.095	0.120	0.099	0.060	0.077	0.063	2%	2%
9	0.061	0.135	0.142	0.039	0.086	0.091	3.8%	Not stated
10	0.299	0.294	0.152	0.191	0.188	0.097	1.6%	1.6%
11	0.731	0.640	0.614	0.467	0.409	0.392	3.1%	3.1%
12	0.145	0.089	0.111	0.093	0.057	0.071	1.33%	1.33%
13	0.631	0.537	0.545	0.403	0.343	0.348	2%	2%
THD	-	-	-	0.87%	0.80%	0.73%	23%	13%
PWHD	-	-	-	2.49%	2.20%	2.10%	23%	22%

THD = Total Harmonic Distortion

PWHD = Partial Weighted Harmonic Distortion

Document no. : 6199027.01COC

3. Power Quality – Voltage fluctuations and Flicker:	P
<p>For Power Generating Modules of Registered Capacity of less than 75 A per phase (ie 50 kW) these tests should be undertaken in accordance with Annex A.7.1.4.3. Results should be normalised to a standard source impedance, or if this results in figures above the limits set in BS EN 61000-3-11 to a suitable Maximum Impedance.</p> <p>For Power Generating Modules of Registered Capacity of greater than 75 A per phase (ie 50 kW) the installation must be designed in accordance with EREC P28.</p> <p>The standard test impedance is 0.4 Ω for a single phase Power Generating Module (and for a two phase unit in a three phase system) and 0.24 Ω for a three phase Power Generating Module (and for a two phase unit in a split phase system). Please ensure that both test and standard impedance are completed on this form. If the test impedance (or the measured impedance) is different to the standard impedance, it must be normalised to the standard impedance as follows (where the Power Factor of the generation output is 0.98 or above):</p> <p>$d \text{ max normalised value} = (\text{Standard impedance} / \text{Measured impedance}) \times \text{Measured value}.$</p> <p>Where the Power Factor of the output is under 0.98 then the X to R ratio of the test impedance should be close to that of the standard impedance.</p> <p>The stopping test should be a trip from full load operation.</p> <p>The duration of these tests needs to comply with the particular requirements set out in the testing notes for the technology under test.</p> <p>The test date and location must be declared.</p>	

Annex



Document no. : 6199027.01COC

Test start date		2024-10-31			Test end date			2024-10-31	
Test location		No.99, Hongye Road, Suzhou Industrial Park, Suzhou, Jiangsu, P.R. China							
Model: PCS2000-108K-MB1									
		Starting			Stopping			Running	
		d(max) [%]	d(c) [%]	d(t) [%]	d(max) [%]	d(c) [%]	d(t) [%]	Pst [%]	Plt 2 hours [%]
Measured Values at test impedance	L1	0.364	0.072	0	0.265	0.072	0	0.0107	0.0106
	L2	0.345	0.158	0	0.300	0.001	0	0.0107	0.0105
	L3	0.348	0.152	0	0.301	0.004	0	0.0107	0.0106
Normalised to standard impedance	L1	0.364	0.072	0	0.265	0.072	0	0.0107	0.0106
	L2	0.345	0.158	0	0.300	0.001	0	0.0107	0.0105
	L3	0.348	0.152	0	0.301	0.004	0	0.0107	0.0106
Normalised to required maximum impedance	L1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	L2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	L3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Limits set under BS EN 61000-3-11		4	3.3	3.3	4	3.3	3.3	1.0	0.65
Test Impedance	R	0.24	Ω	XI	0.15		Ω		
Standard Impedance	R	0.24 * 0.4 ^	Ω	XI	0.15 * 0.25 ^		Ω		
Maximum Impedance	R	N/A #	Ω	XI	N/A #		Ω		
<p>* Applies to three phase and split single phase Power Generating Modules.</p> <p>^ Applies to single phase Power Generating Module and Power Generating Modules using two phases on a three phase system</p>									

Document no. : 6199027.01COC

4. Power quality – DC injection:									P
<p>The tests should be carried out on a single Generating Unit. Tests are to be carried out at three defined power levels $\pm 5\%$. At 230 V a 50 kW three phase Inverter has a current output of 217 A so DC limit is 543 mA. These tests should be undertaken in accordance with Annex A.7.1.4.4.</p> <p>The % DC injection (“as % of rated AC current” below) is calculated as follows: % DC injection = Recorded DC value in Amps / Base current where the base current is the Registered Capacity (W) / Vphase. The % DC injection should not be greater than 0.25%.</p>									
Model: PCS2000-108K-MB1									
Three-phase									
Test power level	10%			55%			100%		
	L1	L2	L3	L1	L2	L3	L1	L2	L3
Recorded DC injection value in Amps	0.353	0.675	1.029	0.331	0.633	0.994	0.371	0.750	0.997
as % of rated AC current	0.08%	0.14%	0.22%	0.07%	0.13%	0.21%	0.08%	0.16%	0.21%
Limit	0.25%			0.25%			0.25%		

5. Power Factor:				P
<p>The tests should be carried out on a single Power Generating Module. Tests are to be carried out at three voltage levels and at Registered Capacity and the measured Power Factor must be greater than 0.95 to pass. Voltage to be maintained within $\pm 1.5\%$ of the stated level during the test. These tests should be undertaken in accordance with Annex A.7.1.4.2</p> <p>Note that the value of voltage stated in brackets assumes a LV connection. This should be adjusted for HV as required.</p>				
Model: PCS2000-108K-MB1				
Voltage	0.94 pu (216.2 V)		1 pu (230 V)	1.1 pu (253 V)
Measured value	0.9999		0.9998	1.0000
Power Factor Limit	> 0.95		> 0.95	> 0.95

Document no. : 6199027.01COC

6. Protection – Frequency tests:						P
These tests should be carried out in accordance with the Annex A.7.1.2.3. For trip tests, frequency and time delay should be stated. For “no trip tests”, “no trip” can be stated.						
Model: PCS2000-108K-MB1						
Function	Setting		Trip test		“No trip tests”	
	Frequency	Time delay	Frequency	Time delay	Frequency /time	Confirm no trip
U/F stage 1	47.5 Hz	20 s	47.40 Hz	20.136 s	47.7 Hz 30 s	No trip
U/F stage 2	47.0 Hz	0.5 s	46.94 Hz	535.95 ms	47.2 Hz 19.5 s	No trip
					46.8 Hz 0.45 s	No trip
O/F	52.0Hz	0.5 s	52.07 Hz	542.50 ms	51.8 Hz 120 s	No trip
					52.2 Hz 0.45 s	No trip
<p>Note: For frequency trip tests the frequency required to trip is the setting ± 0.1 Hz. In order to measure the time delay a larger deviation than the minimum required to operate the projection can be used. The “No trip tests” need to be carried out at the setting ± 0.2 Hz and for the relevant times as shown in the table above to ensure that the protection will not trip in error.</p>						

Document no. : 6199027.01COC

7. Protection – Voltage tests:						P
<p>These tests should be carried out in accordance with Annex A.7.1.2.2. For trip tests, voltage and time delay should be stated. For “no trip tests”, “no trip” can be stated.</p> <p>Note that the value of voltage stated below assumes a LV connection This should be adjusted for HV taking account of the VT ratio as required.</p>						
Model: PCS2000-108K-MB1						
L1-N						
Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V	0.8 pu (184 V)	2.5 s	182.877 V	2.563 s	188 V 5.0 s	No trip
					180 V 2.45 s	No trip
O/V stage 1	1.14 pu (262.2 V)	1.0 s	263.211 V	1.020 s	258.2 V 5.0 s	No trip
O/V stage 2	1.19 pu (273.7 V)	0.5 s	273.921 V	539.4 ms	269.7 V 0.95 s	No trip
					277.7 V 0.45 s	No trip
<p>Note: for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.</p>						

Model: PCS2000-108K-MB1						
L2-N						
Function	Setting		Trip test		“No trip tests”	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V	0.8 pu (184 V)	2.5 s	183.041 V	2.542 s	188 V 5.0 s	No trip
					180 V 2.45 s	No trip
O/V stage	1.14 pu (262.2 V)	1.0 s	263.288 V	1.040 s	258.2 V 5.0 s	No trip
O/V stage 2	1.19 pu (273.7 V)	0.5 s	274.065 V	540.01 ms	269.7 V 0.95 s	No trip
					277.7 V 0.45 s	No trip
<p>Note: for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.</p>						

Document no. : 6199027.01COC

Model: PCS2000-108K-MB1						
L3-N						
Function	Setting		Trip test		"No trip tests"	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V	0.8 pu (184 V)	2.5 s	182.804 V	2.540 s	188 V 5.0 s	No trip
					180 V 2.45 s	No trip
O/V stage 1	1.14 pu (262.2 V)	1.0 s	263.283 V	1.020 s	258.2 V 5.0 s	No trip
O/V stage 2	1.19 pu (273.7 V)	0.5 s	273.834 V	539.23 ms	269.7 V 0.95 s	No trip
					277.7 V 0.45 s	No trip

Note: for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Model: PCS2000-108K-MB1						
L1-L2-L3-N						
Function	Setting		Trip test		"No trip tests"	
	Voltage	Time delay	Voltage	Time delay	Voltage /time	Confirm no trip
U/V	0.8 pu (184 V)	2.5 s	183.041 V	2.519 s	188 V 5.0 s	No trip
					180 V 2.45 s	No trip
O/V stage 1	1.14 pu (262.2 V)	1.0 s	263.093 V	1.045 s	258.2 V 5.0 s	No trip
O/V stage 2	1.19 pu (273.7 V)	0.5 s	274.587 V	540.28 ms	269.7 V 0.95 s	No trip
					277.7 V 0.45 s	No trip

Note: for Voltage tests the Voltage required to trip is the setting ± 3.45 V. The time delay can be measured at a larger deviation than the minimum required to operate the protection. The No trip tests need to be carried out at the setting ± 4 V and for the relevant times as shown in the table above to ensure that the protection will not trip in error.

Document no. : 6199027.01COC

8. Protection – Loss of Mains test:						P
These tests should be carried out in accordance with BS EN 62116. Annex A.7.1.2.4. For test condition A, EUT output = 100 % P _n , test condition B, EUT output = 50 % to 66 % P _n , and test condition C, EUT output = 25 % to 33 % P _n .						
Model: PCS2000-108K-MB1						
The following subset of tests should be recorded in the following table.						
Test Power and imbalance	33% -5% Q	66% -5% Q	100% -5% P	33% +5% Q	66% +5% Q	100% +5% P
Trip time. Limit is 0.5 s	177 ms	206 ms	165 ms	221 ms	208 ms	158 ms

8. Loss of Mains Protection, Vector Shift Stability test:				P
This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip under positive / negative vector shift.				
Model: PCS2000-108K-MB1				
	Start Frequency	Change	Confirm no trip	
Positive Vector Shift	49.5 Hz	+50 degrees	No trip	
Negative Vector Shift	50.5 Hz	- 50 degrees	No trip	

8. Loss of Mains Protection, RoCoF Stability test:				P
This test should be carried out in accordance with Annex A.7.1.2.6. Confirmation is required that the Power Generating Module does not trip for the duration of the ramp up and ramp down test.				
Model: PCS2000-108K-MB1				
Ramp range	Test frequency ramp:	Test Duration	Confirm no trip	
49.0 Hz to 51.0 Hz	+0.95 Hzs ⁻¹	2.1 s	No trip	
51.0 Hz to 49.0 Hz	-0.95 Hzs ⁻¹	2.1 s	No trip	

Document no. : 6199027.01COC

9. Limited Frequency Sensitive Mode – Over frequency test: The test should be carried out using the specific threshold frequency of 50.4 Hz and Droop of 10%. This test should be carried out in accordance with Annex A.7.1.3.					P
Active Power response to rising frequency/time plots are attached if frequency injection tests are undertaken in accordance with Annex A.7.2.4.					
Alternatively, simulation results should be noted below:					
Model: PCS2000-108K-MB1					
Test sequence at Registered Capacity >80%	Measured Active Power Output (W)	Frequency (Hz)	Calculate droop (%)	Primary Power Source	Active Power Gradient
Step a) 50.00 Hz ±0.01 Hz	108545.34	50.00	--	Photovoltaic array simulator	10%
Step b) 50.45 Hz ±0.05 Hz	107451.80	50.45	9.88		
Step c) 50.70 Hz ±0.10 Hz	102022.28	50.70	9.93		
Step d) 51.15 Hz ±0.05 Hz	92306.43	51.15	9.98		
Step e) 50.70 Hz ±0.10 Hz	102010.18	50.70	9.92		
Step f) 50.45 Hz ±0.05 Hz	107429.38	50.45	9.68		
Step g) 50.00 Hz ±0.01 Hz	108530.75	50.00	--		
Test sequence at Registered Capacity 40% - 60%	Measured Active Power Output (W)	Frequency (Hz)	Calculate droop (%)	Primary Power Source	Active Power Gradient
Step a) 50.00 Hz ±0.01 Hz	54207.39	50.00	--	Photovoltaic array simulator	10%
Step b) 50.45 Hz ±0.05 Hz	53124.98	50.45	9.98		
Step c) 50.70 Hz ±0.10 Hz	47729.89	50.70	10.00		
Step d) 51.15 Hz ±0.05 Hz	38012.26	51.15	10.00		
Step e) 50.70 Hz ±0.10 Hz	47640.26	50.70	9.87		
Step f) 50.45 Hz ±0.05 Hz	53110.23	50.45	9.84		
Step g) 50.00 Hz ±0.01 Hz	54212.93	50.00	--		
The frequency at each step should be maintained for at least one minute and the Active Power reduction in the form of a gradient determined and assessed for compliance with paragraph 11.2.3. The Droop should be determined from the measurements between 50.4 Hz and 51.15 Hz. The allowed tolerance for the frequency measurement shall be ± 0.05 Hz. The allowed tolerance for Active Power output measurement shall be ±10% of the required change in Active Power. The resulting overall tolerance range for a nominal 10% Droop is +2.8% and – 1.5%, ie a Droop less than 12.8% and greater than 8.5%.					

Document no. : 6199027.01COC

9-2. Power output with falling frequency test (For PV Inverter):				P
Tests should prove that the Power Generating Module does not reduce output power as the frequency falls. These tests should be carried out in accordance with 11.2.3.1, 12.2.3.1, 13.2.3.1.				
Model: PCS2000-108K-MB1				
Test sequence	Measured Active Power Output (W)	Acceptable Active Power	Frequency (Hz)	Primary power source
50.5 Hz for 5 minutes	108608.28	100% Registered Capacity	50.50	Photovoltaic array simulator
50.0 Hz for 5 minutes	108606.15	100% Registered Capacity	50.00	Photovoltaic array simulator
49.5 Hz for 5 minutes	108603.59	100% Registered Capacity	49.50	Photovoltaic array simulator
49.0 Hz for 5 minutes	108597.63	99% Registered Capacity	49.00	Photovoltaic array simulator
48.0 Hz for 5 minutes	108588.82	97% Registered Capacity	48.00	Photovoltaic array simulator
47.6 Hz for 5 minutes	108588.27	96.2% Registered Capacity	47.60	Photovoltaic array simulator
47.1 Hz for 20 s	108575.93	95% Registered Capacity	47.10	Photovoltaic array simulator

Document no. : 6199027.01COC

9-3	Power output with falling frequency test				P
This test should be carried out in accordance with clause 11.2.3.3, 12.2.3.3, 13.2.3.2 and A.7.1.7					
Model: PCS2000-108K-MB1					
Test 1: 50 Hz to 49.0 Hz, from 100% P _{rated-import}					
Test sequence (Hz)	Measured Active Power Output (W)	Steady frequency (Hz)	P/Pn (%)	Primary power source	
50.0	-108108.18	50.00	-100.10%	AC grid / Storage Battery	
49.5	-108104.67	49.50	-100.10%	AC grid / Storage Battery	
49.2	-43808.29	49.20	-40.56%	AC grid / Storage Battery	
49.0	-356.23	49.00	-0.33%	AC grid / Storage Battery	
Test 2: 50 Hz to 48.8 Hz, from 100% P _{rated-import}					
Test sequence (Hz)	Measured Active Power Output (W)	Steady frequency (Hz)	P/Pn (%)	Primary power source	
50.0	-108091.31	50.00	-100.08%	AC grid / Storage Battery	
49.5	-108092.76	49.50	-100.09%	AC grid / Storage Battery	
49.2	-43780.56	49.20	-40.54%	AC grid / Storage Battery	
49.0	-338.82	49.00	-0.31%	AC grid / Storage Battery	
48.9	21482.60	48.90	19.89%	AC grid / Storage Battery	
48.8	43185.07	48.80	39.99%	AC grid / Storage Battery	
Test 3: 50 Hz to 49.0 Hz, from 40% P _{rated-import}					
Test sequence (Hz)	Measured Active Power Output (W)	Steady frequency (Hz)	P/Pn (%)	Primary power source	
50.0	-43300.98	50.00	-40.09%	AC grid / Storage Battery	
49.5	-43301.67	49.50	-40.09%	AC grid / Storage Battery	
49.2	21157.31	49.20	19.59%	AC grid / Storage Battery	
49.0	64766.80	49.00	59.97%	AC grid / Storage Battery	
Test 4: 50 Hz to 48.8 Hz, from 40% P _{rated-import}					
Test sequence (Hz)	Measured Active Power Output (W)	Steady frequency (Hz)	P/Pn (%)	Primary power source	
50.0	-43292.31	50.00	-40.09%	AC grid / Storage Battery	
49.5	-43291.81	49.50	-40.09%	AC grid / Storage Battery	
49.2	21176.91	49.20	19.61%	AC grid / Storage Battery	
49.0	64771.15	49.00	59.97%	AC grid / Storage Battery	
48.9	86658.01	48.90	80.24%	AC grid / Storage Battery	
48.8	108392.90	48.80	100.36%	AC grid / Storage Battery	


Document no. : 6199027.01COC

10. Protection – Re-connection timer.					P
Model: PCS2000-108K-MB1					
Test should prove that the reconnection sequence starts after a minimum delay of 20 s for restoration of voltage and frequency to within the stage 1 settings of Table 10.1.					
Time delay setting	Measured delay	Checks on no reconnection when voltage or frequency is brought to just outside stage 1 limits of Table 10.1.			
60 s	117.02 s	At 1.16 pu (266.2 V)	At 0.78 pu (180.0 V)	At 47.4 Hz	At 52.1 Hz
Confirmation that the Micro-generator does not re-connect.		No reconnection	No reconnection	No reconnection	No reconnection
Recover to normal operation range after confirmation of no connection		Yes	Yes	Yes	Yes
Confirmation that the Power Generating Module shall reconnect		Reconnection after 117.02 s	Reconnection after 116.74 s	Reconnection after 115.74 s	Reconnection after 115.64 s

Document no. : 6199027.01COC

11. Fault level contribution: These tests shall be carried out in accordance with EREC G99 Annex A.7.1.5.		P
For Inverter output		
Time after fault	Volts	Amps
20ms	142.02 / 87.87 / 55.15	239.04 / 170.05 / 67.94
100ms	0.15 / 0.11 / 0.14	0.48 / 1.26 / 0.57
250ms	0.05 / 0.11 / 0.25	0.47 / 1.25 / 0.58
500ms	0.10 / 0.11 / 0.09	0.48 / 1.23 / 0.58
Time to trip	0.042 s	In seconds

Document no. : 6199027.01COC

12. Self-Monitoring solid state switching: No specified test requirements. Refer to Annex A.7.1.6.	
It has been verified that in the event of the solid state switching device failing to disconnect the Power Park Module , the voltage on the output side of the switching device is reduced to a value below 50 volts within 0.5 s.	N/A
13. Wiring functional tests: If required by para 15.2.1.	
Confirm that the relevant test schedule is attached (tests to be undertaken at time of commissioning)	N/A
14. Logic interface (input port).	
Confirm that an input port is provided and can be used to shut down the module.	Yes
Provide high level description of logic interface, e.g. details in 11.1.3.1 such as AC or DC signal (the additional comments box below can be used)	Yes
15. Cyber security	
Confirm that the Power Generating Module has been designed to comply with cyber security requirements, as detailed in 9.1.7.	Yes Manufacturer's declaration provided
Additional comments.	
<p>Logic Interface:</p> <p>The PCSs can connect to the SmartLogger over FE or to a PC through the SmartLogger to implement communication. You can use the Fusionsolar app, SmartLogger, embedded WebUI, or the network management software (such as the NetEco) on the PC to query information about the PCSs, such as energy yield, alarms, and running status. For example:</p> 	
<ol style="list-style-type: none"> Interface protection has been tested and evaluated on basis of rated grid voltage 3/N/PE~, 230/400 V, 50Hz according to the grid code on page 1. interface protection settings is limited to the authorized installer, password and seal provided to protect these from unpermitted interference. Inverters with multi-voltage and/or frequency ratings are available in difference versions based on output voltages and frequencies, the ratings on which the testing has been based was identified on pater tag and control panel. unauthorised access to factory safety parameters setting and software should be prohibited. A reset to the factory safety parameters requires retesting and verification in conjunction with the end-use system. Protection integrated in inverter can not be used as an alternative central interface protection device at connection point. 	

-End-